



# START-UP CHECK LIST

## AMU w/ Motorized Ball Valve - Temp. Control by Others

MODEL TA \_\_\_\_\_  
 JOB NAME \_\_\_\_\_  
 JOB ADDRESS \_\_\_\_\_  
 INSTALLING CONTRACTOR \_\_\_\_\_  
 TECHNICIAN \_\_\_\_\_

SERIAL # \_\_\_\_\_  
 DATE \_\_\_\_\_  
 SIGNATURE \_\_\_\_\_

### PRESTART CHECKS



- Supply Voltage  
L1 \_\_\_\_\_ L2 \_\_\_\_\_ L3 \_\_\_\_\_
- Motor FLA \_\_\_\_\_
- Installed Fuse/Breaker Size \_\_\_\_\_ Amps
- Control Voltage \_\_\_\_\_
- All Remote Wiring in Place
- All Terminal Connections Tight
- Blower Drive & Hardware Tight
- Inlet Gas Pipe Size \_\_\_\_\_ Inches
- Inlet Gas Pressure \_\_\_\_\_ ("wc) or (PSI)
- All Duct, Unit Accessories and Unit Joints Sealed

### OPERATIONAL CHECKS (cont.)



- VDC to Mod Gas Valve (VM-1) High Fire \_\_\_\_\_
- VDC to Mod Gas Valve (VM-1) High Fire  
Low Speed (if 2<sup>spd</sup>) \_\_\_\_\_
- Burner Modulates from Temp. Control (by others)
- Temp. Controller Provides Stable Discharge Temp.
- Unit Starts and Stops per Sequence of Operation
- Unit Starts and Stops from Time Clock (CLK-1)\*
- Unit Starts and Stops from Unocc Stat (T-3)\*

-----  
 To Mail - Fold on Dotted Line and Seal  
 or FAX to 715 - 597 - 3620

### OPERATIONAL CHECKS



- Service Switches (SW-5 & SW-6)
- Low Temp Limit (LTS-1)\*
- Damper Actuator (DM-1)\*
- Actuator End Switch\*
- Motor Starter (ST-1)
- Motor Amp Draw -  
L1 \_\_\_\_\_ L2 \_\_\_\_\_ L3 \_\_\_\_\_
- Motor Amp Draw - Low Speed (if 2<sup>spd</sup>)  
L1 \_\_\_\_\_ L2 \_\_\_\_\_ L3 \_\_\_\_\_
- Air Flow Switches (P-1 & P-1A)
- Burner Profile Air Press. Drop - \_\_\_\_\_ "wc
- Burner Profile Air Press. Drop - Low Spd. \_\_\_\_\_ "wc
- Inlet Duct Stat (T-1)\*
- High Temp Limit (TL-1)
- Low Gas Press Switch (P-2)\*
- High Gas Press Switch (P-3)
- Flame Safeguard Signal (FS-1)  
Pilot \_\_\_\_\_ VDC Low Fire \_\_\_\_\_ VDC
- Flame Safeguard Trips (FS-1)
- Gas Manifold Pressure  
Burner Off \_\_\_\_\_ "wc
- Burner at High Fire \_\_\_\_\_ "wc
- Burner at High Fire (if 2<sup>spd</sup>) \_\_\_\_\_ "wc

### CONTROL SETTINGS



- Low Temperature Limit (LTS-1)\*
- Time - **3 Minutes** Temperature \_\_\_\_\_ °F
- Motor Overload \_\_\_\_\_ Amps
- Inlet Duct Stat (T-1)\* \_\_\_\_\_ °F
- High Temperature Limit (TL-1) **185°F**
- Low Gas Press Switch (P-2)\* \_\_\_\_\_ "wc
- High Gas Press Switch (P-3) \_\_\_\_\_ "wc
- Temperature Control by Others  
Discharge Temp Setpoint \_\_\_\_\_ °F
- Time Clock Programmed (CLK-1)\*
- Unocc Stat Setting (T-3)\* \_\_\_\_\_ °F

### Additional Comments or Notes:

\_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

\* = Optional control, may not apply to all equipment.